SKG-IKOB PRODUCTCERTIFICATE 555.862.02

Date of issue: 18-06-2024

Certificate holder
Karcher GmbH
Raiffeisenstrasse 32
D-74906 Bad Rappenau
T: +49 7264 91 64 -0
E: mail@karcher-design.de
I: www.karcher-design.de

CERTIFICATE

Declaration of SKG-IKOB
This certificate has been issued on the basis of BRL 3104 in accordance with the SKG-IKOB Regulations for Attestation, Certification and Inspection.

SKG-IKOB declares that the by or on behalf of the certificate owner produced building hardware product:

window handle

delivered under logo / brand:

Karcher

delivered under type- and / or article number:

EF284AB71

meets class 2 STER according BRL 3104 and NEN 5089: 2009 if the product is indelibly marked with the SKG mark, as shown above.

For SKG-IKOB



ir. H.A.J. van Dartel
Certification manager

Verify at www.sterrenwijzer.nl if this certificate is still valid and actual.
This certificate contains 2 pages.

SKG-IKOB Certificatie
Poppenbouwing 56
4191 NZ Geldermalsen

Postbus 202
4190 CE Geldermalsen

T 088-2440100
info@skgikob.nl
www.skgikob.nl

1. PRODUCT
window handle

PRODUCT TYPE
window handle

2. TECHNICAL SPECIFICATION

Operating:	Mechanical operation
Construction:	1 handle with spindle
System:	locking by cylinder
	support: oval OR square
Material:	support: PVC i.c.w. steel and with stainless steel cover
	handle: stainless steel
	spindle: steel zinco coated
Dimension:	support: 70,5x30,8x12,5mm
	spindle: vierk. 7/7 mm x div. lengte
Fixing:	2x M5
Intended use:	PVC, metal, window-inward-opening, window-outward-opening
	for windows in combination with mortice bolts

3. DELIVERY
The preconditions for correct installation and the fasteners to be used are described in the enclosed or digitally published installation instructions with the following version:
versie Nr. 03-16.06.2020

4. PERFORMANCES
A window handle according this certificate fulfils the relevant requirements of BRL 3104.
A window- or door set, in which this window handle is installed according the installation instructions of the certificate holder meets at least burglar resistance class 2 of NEN 5096, if:

- the façade element or the (profile-)system from which the element is manufactured is delivered under a (KOMO-)quality approval with respect to the aspect burglar resistance, in which the actual window or door type is admitted and the herein mentioned conditions are fulfilled.

A window or door, in existing buildings, in which this window handle is installed according the installation instructions of the certificate holder, meets the requirements of the Police Mark Save Housing (PKVW) - Existing Building, if:

- the other aspects of the façade element also comply with the applicable PKVW Protection directive (publication CCV).